Smoke, heat and CO alarm test log

Test at every changeover or at least monthly, as your fire risk assessment requires. Replace units at the end of their life, usually 10 years for smoke and heat alarms and 7 to 10 years for CO alarms.

Property

Address

The alarms

Ref	Location	Type (smoke / heat / CO)	Mains or battery	Interlinked?	Replace by

Tests

Result: OK, or F for a fault (describe it and what was done).

Date	Tested by	All alarms sounded?	Faults and action	Initials

Date	Tested by	All alarms sounded?	Faults and action	Initials